



| TEST | METHOD | DESCRIPTION | RESULTS | |
|-------------|------------------------------|---|---|--|
| FIRE | | | | |
| | ASTM E84 - 21 | Standard Method of Test for Surface Burning Characteristics of Building Materials <i>(The foregoing test procedure is comparable to UL 723, ANSI/NFPA No. 255, and UBC No. 8- 1)</i> | PASS When Tested in Accordance to ASTM E84-21 the Material Resulted in a Class 'A' | Flame Spread 25 Smoke Developed 75 |
| | ASTM E84 - 18b | Standard Method of Test for Surface Burning Characteristics of Building Materials <i>(The foregoing test procedure is comparable to UL 723, ANSI/NFPA No. 255, and UBC No. 8- 1)</i> | PASS When Tested in Accordance to ASTM E84-21 the Material Resulted in a Class 'A' | Flame Spread 20 Smoke Developed 300 |
| | UL 1256 Part II - 4th | Describes a Test Which Appraises Fire Performance of Non-Metallic and Metallic Roof Deck Constructions Subjected to an Internal (Under Deck) Fire Exposure. | Flame Spread < 10 feet in 10 minutes Flame Spread < 14 feet in 30 minutes No Thermal Degradation Through all Components of the Roof Deck Assembly Decreasing Thermal Degradation With Increased Distance From Burner | 3.7 Pass 7.3 Pass Met Pass Met Pass |
| | ASTM D1929-20 | Standard Test Method for Determining Ignition Temperature of Plastics | PASS | Flash-Ignition 387°C 730°F Self-Ignition 429°C 805° |
| | ULC CAN-S127 | Standard Corner Wall Method of Test for Flammability Characteristics of Non-Melting Foam Plastic Building Materials | PASS | Flame Spread <500 for foam core |
| | CAN ULC S102 - 10 | Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies | PASS | Flame Spread 20 Smoke Developed 190 |



| TEST | METHOD | DESCRIPTION | RESULTS | |
|------------------------------|-------------------------------------|---|--|--|
| | CAN/ULC-S138-06 | Fire Growth of Insulated Building Panels in a Full-Scale | Meets Requirements | |
| | NFPA 286 | Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire | Meets Requirements | |
| STRUCTURAL | | | | |
| | ASTM E455, E72 and AISI S907 | Shear Load Tests on Roof and Wall Panels | See Span and Load Tables | |
| | ASTM E1592 | Gravity and Uplift Load Tests on roof Panels | See Span and Load Tables | |
| | ANSI FM 4474 | Standard for Evaluating the Simulated Wind Uplift Resistance of Roof Assemblies | Contact FALK Customer Service | |
| THERMAL | | | | |
| | ASTM C518-21 | Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Meter Apparatus | (R) 7.5 R-VALUE [H.FT ² ·°F/BTU] | |
| AIR | | | | |
| | ASTM E283/E283M-19 | Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Skylights, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen | <0.1 L/s/m ² (<0.01 cfm/ft ²) | |
| | ASTM 1680-16 | Standard Test Method for Rate of Air Leakage through Exterior Metal Roof Panel Systems | <0.01 cfm/ft ² (0.1 L/s/m ²) | |
| WATER | | | | |
| | ASTM E331-00(2016) | Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference | 580 Pa (12.11 psf) | |
| | ASTM E1646-95 | Standard Test Method for Water Penetration of Exterior Metal Roof Panel Systems by Uniform Static Air Pressure Difference Leakage through Exterior Metal Roof Panel Systems | 12.0 psf (575 Pa) Pass 20.0 psf (958 Pa) Pass | |
| SPECIAL | | | | |
| SPECIAL CERTIFICATION | FLORIDA BUILDING CODE | Florida Certificate of Product Approval # FL41818 - Structural Wall Florida Certificate of Product Approval # FL41819 - Structural Roof | Meets Requirements Meets Requirements | |